

**SHEYENNE RIVER, NORTH DAKOTA**

**BALDHILL CREEK**

**BHC-15**

**DAMSITE ANALYSIS**

**14 JUNE 1986**

Sheyenne River, North Dakota

Baldhill Creek: BHC-15

Damsite Analysis

Table of Contents

<u>Item</u>	<u>Page</u>
Introduction	1
Flood Reduction Plans	3
Methodology	4
Existing Frequency Data	5
1-Percent Flood Event	7
Operating Plan	7
Model Results	8
Review of Moore Engineering Report	13

List of Figures

<u>Number</u>		
1	Damsite Location Map	2

List of Tables

<u>Number</u>		
1	Existing Frequency Data	6
2	Peak Flows from HEC-5 Models	9
3	Peak Discharge from 24-hour Rainfall	14
4	Log-Pearson Flow Frequency Analysis	14
5	Corps Frequency Data for Peak Flows	15

## INTRODUCTION

The North Dakota State Water Commission (NDSWC) requested that the flood control effects of a dam proposed for construction on Baldhill Creek be studied. This site has been identified as BHC-15. Figure 1 shows its location.

Baldhill Creek is a tributary of the Sheyenne River, entering the Sheyenne in Lake Ashtabula, the reservoir impounded by Baldhill Dam. Baldhill Dam was constructed in 1950 and is operated for the dual purposes of water supply and flood control. The flood control storage is obtained by drawing down the water supply pool during the winter months in anticipation of spring snowmelt runoff refilling the water supply storage. In 1984 the St. Paul District recommended that the flood control pool at Baldhill Dam be raised by 5 feet to provide more storage that would be available exclusively for flood control. The raise of the flood control pool would require the acquisition of additional property and flowage easements around and upstream of Lake Ashtabula. Concern of potentially affected property owners has prompted the evaluation of other flood control measures as alternatives to the proposed raise of the flood control pool.

This present report addresses the effectiveness that a dam on Baldhill Creek would have on reducing flooding downstream of Baldhill Dam in comparison to raises of the flood control pool at Baldhill Dam.

Also requested and included in this report is a review of the Baldhill Creek Watershed Report done by Moore Engineering for the Upper Sheyenne Joint Water Resource Board, dated January 1985.

DAMSITE LOCATION MAP




FIGURE 1

(After Moore Engineering Report)

Various combinations of flood control pool raises at Baldhill Dam with the proposed Baldhill Creek Dam were evaluated for flood control effectiveness.

#### FLOOD REDUCTION PLANS

- Plan 1 - Existing Baldhill Dam with Existing Baldhill Creek
- Plan 2 - Existing Baldhill Dam with Baldhill Creek Dam
- Plan 3 - Baldhill Dam Flood Control Pool Raised 2.3 feet with Existing Baldhill Creek
- Plan 4 - Baldhill Dam Flood Control Pool Raised 2.3 feet with Baldhill Creek Dam
- Plan 5 - Baldhill Dam Flood Control Pool Raised 5.0 feet with Existing Baldhill Creek
- Plan 6 - Baldhill Dam Flood Control Pool Raised 5.0 feet with Baldhill Creek Dam

Plan 1 was developed so that it is possible to compare an existing conditions model with the various modified conditions models. Since it is not possible to match the gaged flows exactly when developing a computer model, an expected discrepancy is inherently present in all models. Creation of this first model, therefore, allows a better basis for comparison because this same modeling discrepancy is then consistently present throughout.

A number of pool raises of Baldhill Dam, alone and in combination with the proposed Baldhill Creek Dam, have been included in this analysis to give a wider range of alternatives to compare with Plan 2.

## METHODOLOGY

It was requested that the 1969, the 1979, and the 1-percent exceedence frequency flood events be analyzed to assess the benefits of a dam on Baldhill Creek. The HEC-5 computer model was selected for this evaluation because of its capability to model several independent reservoir operations based on the given flood control storage available. This is required since the peak flow from Baldhill Creek tends to occur before the peak on the main stem of the Sheyenne River above Cooperstown.

The capability to modify flows as conditions change downstream requires that the proposed Baldhill Creek Dam have a gated outlet structure. This will increase the cost of the dam, but should also increase economic benefits received from the proposed dam through greater flood damage reduction capabilities.

The reduction of flows for each plan was assessed at three locations below Baldhill Dam - Valley City, Lisbon, and Kindred. Since Valley City is the major damage center below the dam, the greatest benefits from any plan would occur in this area. The other two cities were included in this analysis to ensure that there would be no increase in damages farther downstream as a result of the proposed changes associated with each plan.

Existing Baldhill Dam - Dam Safety: The existing spillway capacity of Baldhill Dam is not large enough to pass the spillway design flood as determined by current criteria. The current spillway capacity is about 43,100 cubic feet per second (cfs); the current spillway design criteria require a capacity of about 126,000 cfs. Modifications to the spillway to increase the capacity and prevent overtopping of the dam are being considered and undertaken through the Corps dam safety program. These dam safety modifications would not change the flood control storage or operation of the Baldhill Dam. However, the dam safety modifications would be accomplished so as not to preclude subsequent changes in the operation or flood control pool.

## EXISTING FREQUENCY DATA

For this study, the frequency data for existing conditions from the "General Reevaluation and Environmental Impact Statement for Flood Control and Related Purposes, Sheyenne River, North Dakota," dated August 1982 were used. This allowed easier comparison of this present analysis with past work done on Bldhill Dam. Table 1 provides the frequency data for existing conditions at various points of interest for this study.

Volume data has also been developed to match that data given in the 1982 report. Data from the 1982 report was unavailable for the gaging stations at Cooperstown and Dazey, North Dakota. Therefore, volume data from WATSTORE with the peak and 1-day frequency curve data from the 1982 report in the Regional Frequency Computer Program was used to develop this information. The volume frequency statistics were adjusted at Dazey (shorter record station) based on the two station comparison method.

TABLE 1, EXISTING FREQUENCY DATA, DISCHARGE IN CFS

COOPERSTOWN

EXCEEDENCE FREQUENCY IN PERCENT	PEAK	1-DAY	3-DAY	7-DAY	15-DAY	30-DAY
0.2	20000	18000	17000	14800	11500	7480
0.5	14500	13200	12600	11000	8600	5670
1.0	11100	10300	9790	8620	6770	4510
2.0	8300	7800	7460	6590	5210	3510
5.0	6950	5140	4940	4390	3500	2390
10.0	3690	3550	3410	3040	2450	1700

BALDHILL CREEK AT DAZEY

EVENT	PEAK	1-DAY	3-DAY	7-DAY	15-DAY	30-DAY
0.2%	23500	15800	10500	7310	4450	2430
0.5%	14500	10200	6980	4940	3070	1710
1.0%	9790	7160	4980	3570	2250	1280
2.0%	6440	4840	3440	2500	1600	931
5.0%	3440	2700	1970	1450	955	572
10.0%	2020	1590	1190	892	599	368
1969	----	2260	1943	1340	----	----
x1.6	----	3616	3109	2149	----	----
x2.0	----	4520	3886	2680	----	----
1979	----	4500	3483	2324	----	----
x1.6	----	7200	5573	3718	----	----
x2.0	----	9000	6966	4648	----	----

BALDHILL DAM INFLOW

EVENT	1-DAY	3-DAY	10-DAY	30-DAY
0.2%	16800	16200	13500	8900
0.5%	13000	12800	10400	6800
1.0%	10400	10200	8380	5480
2.0%	8180	7920	6490	4270
5.0%	5700	5380	4430	2930
10.0%	4080	3810	3140	2090
1969	5275	----	4645	2682
x1.6	8440	----	7432	4291
x2.0	10550	----	9289	5364
1979	9284	----	5686	3274
x1.6	14854	----	9098	5238
x2.0	18568	----	11372	6548

VALLEY CITY

EXCEEDENCE FREQUENCY IN PERCENT	FIS	Pn existing		Pn natural	
		PEAK	M.D.	PEAK	M.D.
0.2	18000	18100	16800	18100	16800
1.0	9400	9400	9000	10900	10400
2.0	5400	5400	5200	8520	8180
10.0	3200	3220	3200	4170	4080



## 1-PERCENT FLOOD EVENT

To determine the 1-percent event for the inflow to Baldhill Dam, it would be necessary to do a period of record routing or a coincidental frequency analysis of the flows from Baldhill Creek, the area above Cooperstown, and the local area at Baldhill Dam. Since this was beyond the level of detail of the present study, the 1-percent flood event was estimated by using a ratio of historic events. Ratios of 1.6 and 2.0 were applied to both the 1969 and the 1979 flood events.

To obtain the 1-percent reduction in flow for Plans 2 through 6, the peak flows from each of these plans were plotted against the peak flows obtained from Plan 1 at Valley City. Curves were plotted which represent the effects of each plan as compared to Plan 1. These curves, when used with the existing frequency curve at Valley City, can estimate the modified frequency curve at Valley City for each plan.

## OPERATING PLAN

In order to evaluate the effectiveness of the various flood control alternatives using the HEC-5 computer model, operating plans were assumed for Baldhill Dam and the proposed dam on Baldhill Creek. A description of these plans follows.

### BALDHILL DAM

The operating plan for the existing Baldhill Dam was used for Plan 1 and Plan 2. Plans 3 through 6 were modeled with the operating plan for the Baldhill Dam that was proposed as part of the 5-foot pool raise for the dam. In general, this plan would function in the following manner.

1. For smaller flood events, outflows from the dam would be limited so that the first peak downstream would not exceed 2,400 cfs at Valley City. This would allow time for levees to be constructed at Valley City if required.

2. For larger flood events, flows would be released early to allow the first peak downstream to be at or below the peak which would have occurred under existing conditions. The expected runoff from the area above Baldhill Dam would be used to determine the discharge required to pass this flow while maintaining the maximum pool within the Baldhill Dam reservoir (Lake Ashtabula).

#### PROPOSED BALDHILL CREEK DAM

For each plan, the proposed Baldhill Creek Dam was operated to maximize the operation of Baldhill Dam by reducing the Baldhill Creek flows with the available storage in the proposed Baldhill Creek Dam.

#### MODEL RESULTS

Using HEC-5, Plans 1 through 6 were run with the 1969 and the 1979 flood events. The two ratios were also applied to each flood event for the six plans. Table 2 contains the peak flows from each of the plans at the three selected locations downstream of Baldhill Dam.

From the tables it can be seen that the results from Plan 2 are similar to the results that would be obtained by implementing Plan 3. The flows from Plans 4 and 5 were also close to each other. Based on this information, the following general statements can be made.

1. Baldhill Creek Dam is equivalent to about a 2.3-foot raise of the flood control pool at Baldhill Dam.

2. Baldhill Creek Dam plus a 2.3-foot raise of the flood control pool at Baldhill Dam is equivalent to about a 5.0-foot raise of the flood pool elevation at Baldhill Dam.

TABLE 2. PEAK FLOWS FROM HEC-5 MODELS

PLAN 1: BALDHILL DAM / BALDHILL CREEK

EVENT	COOP.	BHC	BHDIN	BHDOU	VALLEY CITY		LISBON		KINDRED	
					1st	2nd	1st	2nd	1st	2nd
1969	4890	2260	5275	4765	1415	4696	3925	4565	4553	4493
69x1.6	7824	3616	8440	7932	2144	7754	7074	7534	8004	7379
69x2.0	9780	4520	10550	10126	----	9986	9267	9642	10323	9468
1979	4350	4500	9284	4552	2085	4500	2467	4454	3926	4422
79x1.6	6960	7200	14855	11075	2856	10045	3567	8800	5801	8410
79x2.0	8700	9000	18570	15440	3602	13910	4465	11843	7251	11125

PLAN 2: EXISTING BALDHILL DAM FLOOD CONTROL POOL  
WITH PROPOSED BALDHILL CREEK DAM

EVENT	COOP.	BHC	BHDIN	BHDOU	VALLEY CITY		LISBON		KINDRED	
					1st	2nd	1st	2nd	1st	2nd
1969	4890	230	4884	4247	1415	4183	3912	4066	4505	4006
69x1.6	7824	2000	7914	7202	2144	7008	6858	6733	7804	6591
69x2.0	9780	3000	10356	9803	2680	9491	9018	9066	10081	8895
1979	4350	1008	6421	3687	2085	4070	2458	4074	3926	4047
79x1.6	6960	4000	11831	7852	3033	7511	3636	7040	5801	6826
79x2.0	8700	5000	15089	11741	4023	10769	4648	9760	7252	9307

TABLE 2 (cont.), PEAK FLOWS FROM HEC-5 MODELS

PLAN 3: BALDHILL DAM FLOOD CONTROL POOL RAISED 2.3 FEET

EVENT	COOP.	BHC	BHDIN	BHDOU	VALLEY CITY		LISBON		KINDRED	
					1st	2nd	1st	2nd	1st	2nd
1969	4890	2260	5275	4213	1340	4134	4006	4003	4606	3934
69x1.6	7824	3616	8440	7225	2158	7100	6846	6909	7813	6802
69x2.0	9780	4520	10550	8211	2708	8253	9142	8263	10281	8292
1979	4350	4500	9284	3962	1936	4260	2320	4215	3905	4192
79x1.6	6960	7200	14855	6738	----	6934	4198	6866	5843	6834
79x2.0	8700	9000	18570	11196	3707	10934	4575	10451	7259	10283

PLAN 4: BALDHILL DAM FLOOD CONTROL POOL RAISED 2.3 FEET WITH PROPOSED BALDHILL CREEK DAM

EVENT	COOP.	BHC	BHDIN	BHDOU	VALLEY CITY		LISBON		KINDRED	
					1st	2nd	1st	2nd	1st	2nd
1969	4890	660	5292	2858	1344	2794	3885	2745	4513	2864
69x1.6	7824	1621	8600	5680	2213	5688	6614	5682	7605	5793
69x2.0	9780	2000	10248	8444	2794	8329	8424	8163	9613	8114
1979	4350	1009	6421	3002	1999	3521	2355	3474	3871	3450
79x1.6	6960	4700	12758	6318	3046	6624	3615	6610	5824	6548
79x2.0	8700	6000	16239	7794	----	8234	5360	8239	7286	8155

TABLE 2 (cont.), PEAK FLOWS FROM HEC-5 MODELS

PLAN 5: BALDHILL DAM FLOOD CONTROL POOL RAISED 5.0 FEET

EVENT	COOP.	BHC	BHDIN	BHDOU	VALLEY CITY		LISBON		KINDRED	
					1st	2nd	1st	2nd	1st	2nd
1969	4890	2260	5275	2500	1354	2553	3943	2566	4576	2700
69x1.6	7824	3616	8440	5400	2202	5491	7037	5513	7962	5652
69x2.0	9780	4520	10550	8517	2852	8433	8630	8304	9827	8269
1979	4350	4500	9284	3000	----	3520	2427	3485	3871	3469
79x1.6	6960	7200	14855	6500	3553	6536	3994	6766	5830	6717
79x2.0	8700	9000	18570	8488	----	8356	5490	8404	7296	8354

PLAN 6: BALDHILL DAM FLOOD CONTROL POOL RAISED 5.0 FEET  
WITH PROPOSED BALDHILL CREEK DAM

EVENT	COOP.	BHC	BHDIN	BHDOU	VALLEY CITY		LISBON		KINDRED	
					1st	2nd	1st	2nd	1st	2nd
1969	4890	679	5431	2323	1354	2341	3851	2358	4459	2515
69x1.6	7824	2000	7815	4928	2144	4935	6639	4939	7612	5131
69x2.0	9780	2000	11100	6748	2993	6715	9040	6688	10150	6782
1979	4350	1009	6421	2600	1847	3120	2229	3110	3871	3079
79x1.6	6960	4000	12231	5451	2906	5962	3573	5929	5801	5893
79x2.0	8700	6000	16239	7885	----	8257	5367	8144	7280	8000

Using the discharge-discharge plots for the 1-percent flood event, the following results were obtained at Valley City:

1. Plan 1 (existing conditions)	9,400 cfs
2. Plan 2/Plan 3	8,100 cfs
3. Plan 4/Plan 5	7,100 cfs
4. Plan 6	6,100 cfs

## REVIEW OF MOORE ENGINEERING REPORT

The following is a review of the work done by Moore Engineering Inc., West Fargo, North Dakota as contained in the "Baldhill Creek Watershed, Hydrologic Analysis and Floodwater Retention Study for the Upper Sheyenne Joint Water Resource Board," dated January 1985. Only the data contained in the report and the resulting analysis presented therein which was based on this data were reviewed. Reviewed items which are given below have not been arranged into any particular order.

### Computer Model Development.

1. Given the characteristics of Baldhill Creek subbasin, hypothetical storms having durations greater than 24 hours should also have been analyzed.

2. The Soil Conservation Service (SCS) Type I Rainfall Distribution was used in the Moore study. With the exception of Minnesota and North Dakota, the remaining States use a Type II Rainfall Distribution. This latter approach would have produced a more critical event than the Type I distribution. The Corps determines synthetic storms using methods that produce results similar to those produced by the Type II SCS distribution method. It is our opinion that the Type II Rainfall Distribution would have been the method of choice for this analysis.

3. There is a gaging station on Baldhill Creek at Dazey, North Dakota. Data from this station should have been used to calibrate subbasin characteristics. (Table 3 lists the peak flows from the HEC-1 model for a 24-hour rainfall event at location BHC-021 which is just upstream of the Dazey gaging station.)

Table 3, Peak Discharge from 24-hour Rainfall Upstream of the  
Dazey Gaging Station for Selected Frequencies

Gaging Station	Frequency of Discharge - Years			
	10	25	50	100
Baldhill Creek	5,426	7,707	10,297	13,476

Existing Gaging Station Data.

A Log Pearson Type III frequency analysis was done for 4 gaging stations in the study area. The gages are: Baldhill Creek near Dazey, and the Sheyenne River near Cooperstown, below Baldhill Dam, and at Valley City.

Table 4 shows the results obtained in the Moore Engineering Report from the Log-Pearson Type III Frequency Analysis. For comparison, table 5 contains the Corps frequency data for peak flows at the same locations. There are differences between the values presented at Dazey and Cooperstown which can be accounted for by the different level of detail and the different period of record used.

Table 4, Log-Pearson Flow Frequency Analysis, Discharge in cfs

Gaging Station	Years of Record	Frequency of Discharge - years							
		1	2	5	10	25	50	100	500
Baldhill Creek near Dazey	28	7	280	980	1,865	3,650	5,595	8,175	17,360
Sheyenne River nr Cooperstown	38	83	1,095	2,475	3,695	5,560	7,175	8,960	13,790
Sheyenne River at Valley City	43	111	1,075	2,160	3,040	4,290	5,310	6,390	9,120



Table 5, Corps Frequency Data for Peak Flows in cfs

Gaging Station	Years of Record	Frequency of Discharge - years							
		1	2	5	10	25	50	100	500
Baldhill Creek near Dazey	42*				2,020	3,440	6,440	9,790	23,500
Sheyenne River nr Cooperstown	42*				3,690	6,950	8,300	11,100	20,000
Sheyenne River at Valley City	42* FIS				3,200		5,400	9,400	18,000
	42* Pn existing				3,220		5,400	9,400	18,100
	42* Pn natural				4,170		8,520	10,900	18,100

\* Equivalent length of record based on two-station comparison

1. While the Log-Pearson III frequency analysis can be used at Dazey and Cooperstown, it is not applicable for the gaging stations at Baldhill Dam and Valley City according to the "Guidelines For Determining Flood Flow Frequency, Bulletin #17B, revised September 1981, editorial corrections March 1982," pages 2 and 3.

2. The 1979 peak flows at Dazey should have been adjusted according to Bulletin #17B guidelines, since the peak for this year was caused in part by a road failure.

3. During a Flood Insurance Study conducted by the Corps, consideration was given to the method used by Moore Engineering to obtain the 6,390 cfs value at Valley City. This value was rejected in a joint meeting held with the NDSWC on October 16, 1980 in Bismarck, North Dakota.

4. The data for Dazey computed by Moore Engineering using rainfall data and the Log-Pearson method do not agree. Currently in the report, there are two frequency curves at Dazey for the same condition. Given the

available data, the gaged data should have been used to calibrate the HEC-1 model using rainfall.

5. The purpose of the Moore Engineering study was to determine the effects of a dam on Baldhill Creek. Since the volume of flood events should be an important aspect of this analysis, volume-frequency curves should be computed. These were not included in the report.